



Titan

Technical Data Sheet

DESCRIPTION	Composite Cavity Fire Barrier Combined integrity and insulation
APPLICATION	Vertical or Horizontal
CERTIFICATION	Third Party Certification by Certifire / CF800
WEIGHT	3.9kg/m ² nominal
THICKNESS	15mm nominal
BS 476 PART 6 FIRE PROPAGATION TEST WIRA Testing Centre	Fire Propagation Index 2.56
BS 476 PART 7 SURFACE SPREAD OF FLAME WIRA Testing Centre	Certification to "Class 1" pass
BS 476 CLASS "0" BUILDING REGULATIONS WIRA Testing Centre	Complies with requirements.
BS 476 PART 20/22 1987 CLAUSE 5 Assessed to the criteria of BS.476 Part 22: 1987 By Helios Consultants Ltd Warrington Bodycote Fire Assessment No: WF170678	INTEGRITY: 120 MINUTES INSULATION: 60 MINUTES
BS 476 PART 20:1987/PREN 1366-3: 1993 PENETRATION SYSTEM Warrington Fire Research	INTEGRITY: 60 MINUTES
SOUND REDUCTION INDEX IN ACCORDANCE WITH THE PRINCIPLES OF BS EN ISO 140/III 1995	19dB - As a stand alone product 49dB - When installed in conjunction with a mineral fibre tiled type ceiling

FIREFLY TITAN complies with the requirements of Building Regulations 2006 Approved Document B, Appendix A, table A1, item 16.

PACK SIZES	LENGTH: 6 metres nominal WIDTH: 130 cms nominal WEIGHT: 30.41 Kg nominal
------------	--

FIREFLY TITAN to be fitted in accordance with manufacturer guidelines.

FF 09/12



Certificate Number GB93/1784



APPROVED PRODUCT
CF 800

TBA TEXTILES LTD
Unit 3, Transpennine Trading Estate,
Gorrells Way, Rochdale
OL11 2PX
England

Dir Tel: +44 1706 758817
Int. Fax: +44 1706 750256
Email: info@tbafirefly.co.uk
Web: www.tbafirefly.co.uk